

T SWIVEL ADAPTOR

Ex db, Ex eb, Ex ta, IP65/66/68

for General Industrial and Hazardous Area Installations

Features and Benefits

- Precision manufactured from high quality brass (Marine Grade Electroless Nickel Plated™).
- Supplied with sealing gasket as standard.
- Fitted with a silicone O-ring as standard.
- Can be fixed in any position around a 360° circle.
- Available in Metric and BSPP male thread forms and Metric, BSPP, BSPT and NPT female thread forms.





Technical Data

T Swivel Adaptor Type:

Material:

Brass (Marine Grade Electroless Nickel Plated™) Body and nut: Standard HDPE or Extreme Temp. PTFE Sealing gasket:

O-ring: Silicone

Note: The installer should ensure that the materials are suitable for the installation

environment.

Standards and Certifications

Equipment Protection Levels: IECEX: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da

ATEX/UKEX: (a) I M2 Ex db I Mb, Ex eb I Mb; (b) II 2 G, 1 D Ex db IIC Gb,

Ex eb IIC Gb, Ex ta IIIC Da

NEC / CEC: Class I Div. 1/Div. 2 Gr ABCD; Class II Div. 1 Gr EFG/ Div. 2 Gr FG; Class III Div.1/Div.2; Class I Zone 1 AEx db IIC Gb /Ex db IIC Gb Class I Zone 1 AEx eb IIC INMETRO: Ex db I Mb, Ex eb I Mb, Ex db IIC Gb, Ex eb IIC Gb, Ex tb IIIC Db

-20°C to +95°C (HDPE sealing gasket) or -60°C to +160°C (PTFE sealing gasket) Operating temperature range:

Conformance: Standard: Certificate:

IECEx IEC 60079 Part 0, 1, 7, 31 IECEx CML16.0059U EN 60079 Part 0, 1, 7, 31 **ATEX** CML 16ATEX1137U UKFX BS EN 60079 Part 0, 1, 7, 31 CML 21UKEX1012U

NEC UL514B, UL2225, UL60079 Part 0, 1, 7, 31

CFC CSA C22.2 No. 18.3-12, 174 CSA C22.2 No. 60079 Part 0, 1, 7, 31

ABNT NBR IEC 60079-0, 1, 7, 31 **INMETRO** TÜV 16.1856U SANS SANS/IEC 60079 Part 0, 1, 7, 31 MASC MS/16.1806U

IP66/68 - Parallel IEC 60529 IP65 - Tapered IEC 60529 Deluge Protection DTS-01

IEC 60079 Part 0, 1, 7, 15, 31 Marine ABS


and IEC 60529

LR1537/2

CML 15Y728

CML 14CA370-2

ABS 20-SG1952706-1 PDA



PATENTED

TABS SPROVED MAJOR

Conditions for Safe Use

- The service temperature range of -20°C to +95°C (HDPE sealing gasket) or -60°C to +160°C (PTFE sealing gasket) shall not be exceeded.
- All adaptors are rated IP65 for any sealing arrangement. If an IP rating of IP66/67/68 is required then the supplied sealing gasket shall be used

	Product Code	Male Thread		Female Thread		Nut Hexagonal Details		Installation
		Туре	Minimum Length 'A'	Туре	Minimum Length 'B'	Maximum 'Flats'	Maximum 'Crns'	Torque Value Nm
	ATM20M20E	M20x1.5-6g	17.0	M20x1.5-6g	16.0	27.0	30.4	21.0
	ATM25M25E	M25x1.5-6g	17.0	M25x1.5-6g	16.0	35.0	39.4	30.0
	ATM32M32E	M32x1.5-6g	17.0	M32x1.5-6g	16.0	40.0	45.0	42.0
	ATM20N012E	M20x1.5-6g	17.0	½" NPT	16.0	27.0	30.4	21.0
	ATM25N034E	M25x1.5-6g	17.0	¾" NPT	16.0	35.0	39.4	30.0
	ATM32N001E	M32x1.5-6g	17.0	1" NPT	16.0	40.0	45.0	42.0

All dimensions except NPT are in mm. For other thread types, contact CCG.

FITTING INSTRUCTIONS

Metric Illustration

CABLE TERMINATIONS

T SWIVEL ADAPTOR

 The locking nut must be fully tightened onto the male thread before installing the adaptor.



Ensure that the threaded entry on the equipment has a flat, square surface
to engage the sealing gasket. Tighten the adaptor, complete with sealing
gasket, into the equipment until it is fully secured noting the maximum
torque figures in the table overleaf.



- 3. Unscrew the adaptor a maximum of 360° until it is pointing in the desired direction.
- 4. Hold the adaptor in the required orientation with a spanner and tighten the locking nut noting the maximum torque figures in the table overleaf.



 Check that the O-ring seal is not visible (this ensures that the required number of threads are engaged in the equipment). If the O-ring is visible then repeat steps 1 to 4 correctly.

6. Hold the T-Swivel Adaptor flats using a spanner whilst fitting a cable gland to the female thread.

