

## UK Type Examination Certificate CML 21UKEX1011X Issue 3

### United Kingdom Conformity Assessment

- 1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended) – Schedule 3A, Part 1
- 2 Equipment **Cable Gland Series E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, FLP-TR (QS)(VX), FLP-TR-KHDE (QS)(VX), FLPHOSE (QS)(VX), VRTX, UNITEx-D (VS), UNITEx-E, UNITEx-QS(VX), UNITEx-F, UNITEx F~QS(VX), TMC, TMCX**

3 Manufacturer **CCG Cable Terminations PTY LTD**

4 Address **33-37 Forge Road,  
Spartan Ind Area,  
Kempton Park, 1619,  
South Africa**

5 The equipment is specified in the description of this certificate and the documents to which it refers.

6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, Approved Body Number 2503, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.

7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section 14.

8 This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN 60079-1:2014

EN IEC 60079-7:2015/A1:2018

EN 60079-31:2014

10 The equipment shall be marked with the following:



II 2G 1D



I M2



II 2G 1D

Ex db IIC Gb

Ex db I Mb

Ex eb IIC Gb

IP66/67/68 (2m), IP65 (as applicable)

Ex eb IIC Gb

Ex eb I Mb

Ex ta IIIC Da

Refer to description for specific marking

Ex ta IIIC Da

IP66/68 (2m)

IP66/68 (2m)






**CML 21UKEX1011X  
Issue 3**

## 11 Description

Cable glands for use with armoured cables, Types; E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, UNITEx-D (VS), UNITEx-E, UNITEx-QS (VX), UNITEx-F, UNITEx-F~QS(VX), TMC, TMCX.

Cable glands for use with non-armoured and braid cables, Types; FLP-TR (QS)(VX), FLP-TR- KHDE (QS)(VX), FLPHOSE (QS)(VX), VRTX.

Product	Sizes	Ex db IIC Gb	Ex eb IIC Gb	Ex db I Mb	Ex eb I Mb	Ex ta IIC Da
ARMORTEX (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
E1EX U (VS)(QS)(VX)	00-10 (Metric & NPT)	✓	✓	✓	✓	✓
FLP (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
FLP Hose (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
FLP TR (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
FLP-TR-KHDE (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓
D1EX (QS)(VX)	00-13 (Metric) 00-11 (NPT)	✓	✓			✓
E1EX (VS)(QS)(VX)	00-13 (Metric) 00-11 (NPT)	✓	✓			✓
E1EX Lead Seal	00-13 (Metric) 00-11 (NPT)	✓	✓			✓
EXCG (VS)(QS)(VX)	00-10 (Metric)	✓	✓			✓
EXCG – Lead Seal	00-13 (Metric)	✓	✓			✓
UNITEx-D (VS)	00-10 (Metric & NPT)	✓	✓			✓
UNITEx ~QS(VX)	00-10 (Metric & NPT)	✓	✓			✓
UNITEx-F~ QS(VX)	00-10 (Metric & NPT)	✓	✓			✓
TMCX	00-11 (Metric & NPT)	✓	✓			✓
CXe	00-13 (Metric) 00-11 (NPT)		✓			✓
CWe	00-13 (Metric) 00-11 (NPT)		✓			✓
TMC	00-11 (Metric & NPT)		✓			✓
UNITEx-E	00-10 (Metric & NPT)		✓			✓
UNITEx-F	00-10 (Metric & NPT)		✓			✓
VRTX	0-8 (Metric)		✓			✓
VRTX SWA	0-8 (Metric)		✓			✓



CML 21UKEX1011X  
Issue 3

### Notes

1. Cable glands with parallel entry threads are IP66/68 when fitted with the supplied sealing gasket. NPT threads are at least IP65 as standard, but IP68 (2m) can be achieved if one of the following grease types is applied to the NPT thread before fitting:- Renolit Lubrene CA 700, Renolit LC-WP2, Renolit Lubrene LX 220 EP2, Renolit Moly LX 2 or Dow Corning 4 Electrical Compound.
2. Cable glands with parallel entry threads (e.g. Metric and BSP parallel) are supplied with fitted sealing gaskets as standard. The sealing gasket is optional for Ex d applications without IP rating. (RE-FLEx cord may be used as an alternative to a standard sealing gasket.)
3. 'VS' in the name of a cable gland variant indicates that a thin copper/brass disc is fitted between the inner seal and the cone for earth continuity to a metallic cable screen (e.g. variable speed drive cable or a lead sheathed cable). The sealing arrangement between the inner seal and the potted sleeve is not affected. Note that a standard cable gland type can be converted to a (VS) variant by retrofitting the thin copper / brass disc. The product marking does not need to be changed when the copper / brass disc is retrofitted.
4. '-FC' in the name of a cable gland variant indicates that the outer seal nut has an additional female thread to allow the connection of a flexible conduit.
5. 'QS' in the name of a cable gland variant, indicates that it is the Quickstop resin barrier version of the cable gland. This utilises a clear potting compound to achieve a hard setting seal inside the gland. The sealing compound is transparent and accommodates inspection.
6. 'VX' in the name of a cable gland variant, refers to the Vortex resin barrier version of the cable gland. This utilises a coloured potting compound to achieve a hard setting seal inside the gland. There is a transparent elastomeric seal at the end of the compound enclosure to accommodate inspection.
7. Cable glands that are available as both barrier (QS or VX) and non-barrier versions may be supplied as non-barrier versions together with the additional components needed to convert them to barrier versions if required. When the conversion is carried out the product marking does not need to be changed
8. RE-FLEx sealing cord can be used as an alternative to a standard sealing gasket to achieve IP66/68. It is intended as a retro-fit solution and must be installed according to the fitting instructions supplied with it.

### Materials of Manufacture

- Brass (CZ121), Bronze (PB2), Stainless Steel (316), Aluminium (6063), Mild steel (EN8)
- HDPE (D7255/HL), PTFE (CCG PTFE-001), Nylon (6)
- EPDM (64 Shore), Silicone (CCG G/65-1C)
- QuickStop Ex resin (S50/EPA or FR/846), VORTEX Ex resin (S50/Y, EPA/Y or FR/846/Y)



CML 21UKEX1011X  
Issue 3

### Variation 1

This variation introduced the following modifications:

- i. The introduction of an alternative seal arrangement on the UNITEx-D gland range.
- ii. To allow an alternative QuickStop and VORTEX resin to be used, giving a wider temperature range.
- iii. To include IPX8 rating on NPT threaded arrangements when used with specific greases.
- iv. The description and specific Conditions of Use have been updated in accordance with the modifications above.
- v. To correct the CXe gland cable acceptance ranges.

### Variation 2

This variation introduced the following modifications:

- i. To update the certificate format, and where applicable, the description has been updated in accordance with the modifications.
- ii. To update the number of cores allowed in size 00 and 0 barrier glands from 6 to 10.
- iii. To update the UNITEx~QS(VX) cable gland to use the E1EX cable gland outer seal arrangement.
- iv. To update the certification to add the option for any cable gland to have an outer seal nut with an additional female thread to allow flexible conduits to be attached to the cable gland (designated '-FC').
- v. The addition of new gland model variant FLP-TR-KHDE. (A FLP-TR gland with an addition to the rear nut to allow a specific pipe connection – the pipe is used to protect the cable fitted.)
- vi. To update the certification drawings with minor corrections.
- vii. To update the A2F-FHC~QS gland certification drawings to show additional NPT entry thread options and to remove model A2F-FHC from the certificates detailed on the front page.
- viii. To update the coding from Ex tb IIIC Db to Ex ta IIIC Da.
- ix. To permit changes to the Conditions of Manufacture and Specific Conditions of Use.
- x. To update the wording of the grease used for the NPT threads.
- xi. Correction to standards referenced.

### Variation 3

This variation introduced the following modifications:

- i. To include a modified TMCX design.
- ii. To remove the barrier gland versions of the A2EX, A2F-FHC, and PosiGrip glands.
- iii. To remove the non-barrier gland versions of the A2EX, and PosiGrip glands.
- iv. To update the number of cores allowed in barrier gland versions.
- v. To allow an alternate outer seal nut assembly to be used in the UNITEx-F~QS (VX) gland.
- vi. To permit changes to the Specific Conditions of Use.
- vii. To update the material options for the VaritEx gland spring.
- viii. To update the existing certification text, and where applicable, the certification drawings.



CML 21UKEX1011X  
Issue 3

## 12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	25 Jan 2021	R13654F/00	Issue of Prime Certificate
1	14 Apr 2021	R13990A/00	Introduction of Variation 1
2	28 Apr 2022	R15091A/00	Introduction of Variation 2
3	27 Sept 2023	R16748A/00	Introduction of Variation 3

Note: Drawings that describe the equipment are listed in the Annex.

## 13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate.
- ii. Cable glands with intermediate metric entry thread sizes shall be constructed by enlarging the entry thread size of the standard size product immediately below the intermediate thread size. The minimum entry wall thickness, allowable number of cores, cable size range and constructional parts utilised (other than the entry thread component) shall not differ from that of the standard size used.
- iii. When constructed of aluminium, the glands shall not be marked for Group I applications.



CML 21UKEX1011X  
Issue 3

## 14 Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

### General Conditions

- i. The cable glands shall only be used where the temperature, at the point of entry, is between:
  - Quickstop or Vortex resin type S50 / EPA, when used with any gaskets/skid rings:  
(-50°C and +95°C)
  - Quickstop or Vortex resin type FR/846, when used with EPDM seals & Nylon gaskets/skid rings or Silicone seals & PTFE gaskets / skid rings:  
– (-60°C and +100°C)
  - EPDM seals & HDPE gaskets/skid rings:  
(-60°C and +95°C)
  - EPDM seals & Nylon gaskets/skid rings:  
(-60°C and +100°C)
  - Silicone seals & PTFE gaskets/skid rings:  
(-60°C and +160°C)
  - The corrosion guard is not an essential part of the explosion protection. The corrosion guard material has a Relative Temperature Index (RTI) of 120°C.
- ii. Cable glands for unarmoured or braided cable and approved only for Group IIC/IIIC (Not barrier glands or Group I) shall only be used on fixed installations where the cable is clamped, or stress applied to the cable in the gland is prevented.
- iii. When constructed of aluminium, the glands shall not be used in Group I applications.
- iv. When the RE-FLEEx sealing method is used, the gland installer shall refer to the manufacturer's instructions.

### Conditions for Specific Glands

- i. VRTX range of glands:
  - The VRTX range of cable glands shall only be used on fixed installations where the cable is clamped, or stress applied to the cable in the gland is prevented
- ii. Armortex and E1EX-U type ranges of glands
  - The Armortex and E1EX-U type glands have been tested for braided cable for Group II and III only. When braided cable is fitted, they shall only be used on fixed installations where the cable is clamped or stress applied to the cable in the gland is prevented. (Does not apply to barrier gland versions.)

# Certificate Annex



**Certificate Number** CML 21UKEX1011X

**Equipment** Cable Gland Series E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, FLP-TR (QS)(VX), FLP-TR-KHDE (QS)(VX), FLPHOSE (QS)(VX), VRTX, UNITE<sub>x</sub>-D (VS), UNITE<sub>x</sub>-E, UNITE<sub>x</sub>-QS(VX), UNITE<sub>x</sub>-F, UNITE<sub>x</sub>-F-QS(VX), TMC, TMCX

**Manufacturer** CCG Cable Terminations PTY LTD

The following documents describe the equipment defined in this certificate:

## Issue 0

Drawing No	Sheets	Rev	Approved date	Title
0468 MARK	1 of 1	1	25 Jan 2021	A2F-FHC(QS) GLAND MARKING
0521 - MARK ATEX&IECE <sub>x</sub>	1 of 1	1	25 Jan 2021	No. "X" FLP, ARMORTEX MARKING
0523 - MARK ATEX&IECE <sub>x</sub>	1 of 1	1	25 Jan 2021	No."X" EX GLAND MARKING
0523-LS MARK ATEX&IECE <sub>x</sub>	1 of 1	1	25 Jan 2021	No. "X" E1EX - LS AND - U GLAND MARKING
0531-MARK ATEX&IECE <sub>x</sub>	1 of 1	1	25 Jan 2021	No."X" VRTX GLAND MARKING
0537 - MARK ATEX&IECE <sub>x</sub>	1 of 1	1	25 Jan 2021	A2EX-FHC GLAND MARKING
0545- MARK ATEX&IECE <sub>x</sub>	1 of 1	1	25 Jan 2021	No."X" POSI GRIP MARKING
0557-MARK	1 of 1	1	25 Jan 2021	CWe / CXe GLAND MARKING
0587-MARK	1 of 1	1	25 Jan 2021	No."X" UNITE <sub>x</sub> -F(QS) - MARK
0591 - MARK ATEX&IECE <sub>x</sub>	1 of 1	2	25 Jan 2021	No."X" UNITE <sub>x</sub> GLAND MARKING
0595 - 0589 MARKING ATEX-IECE <sub>x</sub>	1 of 1	1	25 Jan 2021	TMC / TMCX MARKING - ATEX-IECE <sub>x</sub>

## Issue 1

Drawing No	Sheets	Rev	Approved date	Title
0468 MARK	1 of 1	1	14 Apr 2021	A2F-FHC (QS) GLAND MARKING
0510-ASSY	1 of 1	5	14 Apr 2021	No. "X" UNITE <sub>x</sub> -F GLAND ASSY
0521-MARK ATEX&IECE <sub>x</sub>	1 of 1	1	14 Apr 2021	No. "X" FLP, ARMORTEX MARKING

# Certificate Annex



**Certificate Number** CML 21UKEX1011X

**Equipment** Cable Gland Series E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, FLP-TR (QS)(VX), FLP-TR-KHDE (QS)(VX), FLPHOSE (QS)(VX), VRTX, UNITE<sub>x</sub>-D (VS), UNITE<sub>x</sub>-E, UNITE<sub>x</sub>~QS(VX), UNITE<sub>x</sub>-F, UNITE<sub>x</sub> F~QS(VX), TMC, TMCX

**Manufacturer** CCG Cable Terminations PTY LTD

Drawing No	Sheets	Rev	Approved date	Title
0523 - MARK ATEX&IECE <sub>x</sub>	1 of 1	1	14 Apr 2021	No. "X" EX GLAND MARKING
0523-LS MARK ATEX&IECE <sub>x</sub>	1 of 1	1	14 Apr 2021	No. "X" E1EX – LS AND –U GLAND MARKING
0531-I -SWA	1 of 1	1	14 Apr 2021	No. "X" VRTX INNER
0531-MARK ATEX&IECE <sub>x</sub>	1 of 1	1	14 Apr 2021	No. "X" VRTX GLAND MARKING
0537 - MARK ATEX&IECE <sub>x</sub>	1 of 1	1	14 Apr 2021	A2EX-FHC GLAND MARKING
0545- MARK ATEX&IECE <sub>x</sub>	1 of 1	1	14 Apr 2021	No. "X" POSI GRIP MARKING
0547-ASSY	1 of 1	6	14 Apr 2021	No. "X" Ex de CORROSION GUARD
0554-ASSY	1 of 1	6	14 Apr 2021	No. "X" UNITE <sub>x</sub> -D GLAND ASSY
0554-B	1 of 1	3	14 Apr 2021	No. "X" UNITE <sub>x</sub> -D BODY
0554L-ASSY	1 of 1	1	14 Apr 2021	No. "X" UNITE <sub>x</sub> -D COMBINATION GLAND ASSY
0557-MARK	1 of 1	1	14 Apr 2021	CWe / CXe GLAND MARKING
0559-ASSY	1 of 1	5	14 Apr 2021	No. "X" UNITE <sub>x</sub> ~QS GLAND ASSY
0587-ASSY	1 of 1	5	14 Apr 2021	No. "X" UNITE <sub>x</sub> -F~QS GLAND ASSY
0587-I	1 of 1	3	14 Apr 2021	No. "X" UNITE <sub>x</sub> -F~QS INNER
0587-MARK	1 of 1	1	14 Apr 2021	No. "X" UNITE <sub>x</sub> -F(QS)-MARK
0591-MARK ATEX&IECE <sub>x</sub>	1 of 1	2	14 Apr 2021	No. "X" UNITE <sub>x</sub> GLAND MARKING
0595 - 0589 MARKING -ATEX-IECE <sub>x</sub>	1 of 1	1	14 Apr 2021	TMC / TMCX MARKING – ATEX-IECE <sub>x</sub>
8055 - SG	1 of 1	1	14 Apr 2021	No. "X" CCG SEALING GASKET
057000-16057010	1 of 1	5	14 Apr 2021	No. "X" CXe GLAND ASSEMBLY
057001 - 057004 -B	1 of 1	1	14 Apr 2021	No. "X" CXe BODY



# Certificate Annex



**Certificate Number** CML 21UKEX1011X

**Equipment** Cable Gland Series E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, FLP-TR (QS)(VX), FLP-TR-KHDE (QS)(VX), FLPHOSE (QS)(VX), VRTX, UNITE<sub>x</sub>-D (VS), UNITE<sub>x</sub>-E, UNITE<sub>x</sub>-QS(VX), UNITE<sub>x</sub>-F, UNITE<sub>x</sub> F-QS(VX), TMC, TMCX

**Manufacturer** CCG Cable Terminations PTY LTD

## Issue 2

Drawing No.	Sheets	Rev	Approved Date	Title
0468 MARK	1 of 1	2	28 Apr 2022	A2F-FHC~QS(VX) GLAND MARKING
0519 -ASSY	1 of 1	6	28 Apr 2022	No. "X" D1EX Ex de CABLE GLANDS
0521 – MARK ATEX&IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	No. "X" FLP, ARMORTEX MARKING
0521- ASSY	1 of 1	5	28 Apr 2022	No. "X" FLP GLAND ASSEMBLY
0521-FC-C	1 of 1	-	28 Apr 2022	No. "X" FLP-FC CONE
0522- ASSY	1 of 1	5	28 Apr 2022	No. "X" ARMORTEX GLAND ASSEMBLY
0523-ASSY-SL	1 of 1	4	28 Apr 2022	TYPICAL QUICK STOP AND VORTEX SLEEVE ASSEMBLY
0523 - MARK ATEX&IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	No. "X" EX GLAND MARKING
0523 D - B	1 of 1	1	28 Apr 2022	No. "X" E1EX BODY
0523 D - I	1 of 1	1	28 Apr 2022	No. "X" E1EX INNER
0523-LS ASSY	1 of 1	5	28 Apr 2022	No. "X" E1EX LEAD SEAL ASSY
0523-LS MARK ATEX&IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	No. "X" E1EX - LS AND - U GLAND MARKING
0524- ASSY	1 of 1	5	28 Apr 2022	No. "X" FLP TR ASSEMBLY
0524-FC ASSY	1 of 1	-	28 Apr 2022	No. "X" FLP-TR-FC FLEXIBLE CONDUIT ASSEMBLY
0524-FC-O	1 of 1	-	28 Apr 2022	No. "X" FLP-TR-FC OUTER
0524-O-D	1 of 1	-	28 Apr 2022	No. "X" FLP TR DIESEL OUTER
0524-KHDE-ASSY	1 of 1	-	28 Apr 2022	No. "X" FLP-TR-KHDE GLAND ASSEMBLY
0527- HOSE ASSY	1 of 1	5	28 Apr 2022	FLP HOSE GLAND ASSEMBLY
0527-FC-ASSY	1 of 1	-	28 Apr 2022	No. "X" FLP-FC FLEXIBLE CONDUIT GLAND ASSEMBLY
0527-FC-MARK ATEX,UKEX&IECE <sub>x</sub>	1 of 1	-	28 Apr 2022	FLP-FC, FLP-TR-FC & FLP-TR-KHDE MARKING- ATEX,UKEX&IECE <sub>x</sub>
0527-FC-O	1 of 1	-	28 Apr 2022	No. "X" FLP-FC OUTER
0531-VRTX	1 of 1	4	28 Apr 2022	No. "X" VRTX GLAND ASSEMBLY
0531-MARK ATEX&IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	No. "X" VRTX GLAND MARKING
0536-ASSY	1 of 1	9	28 Apr 2022	No. "X" A2EX ASSEMBLY
0537 - ASSY	1 of 1	6	28 Apr 2022	No. "X" A2EX FHC GLAND ASSEMBLY
0537 - MARK ATEX&IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	A2EX-FHC GLAND MARKING
0545 - ASSY	1 of 1	4	28 Apr 2022	No. "X" POSI GRIP ASSEMBLY

# Certificate Annex



**Certificate Number** CML 21UKEX1011X

**Equipment** Cable Gland Series E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, FLP-TR (QS)(VX), FLP-TR-KHDE (QS)(VX), FLPHOSE (QS)(VX), VRTX, UNITE<sub>x</sub>-D (VS), UNITE<sub>x</sub>-E, UNITE<sub>x</sub>-QS(VX), UNITE<sub>x</sub>-F, UNITE<sub>x</sub> F-QS(VX), TMC, TMCX

**Manufacturer** CCG Cable Terminations PTY LTD

Drawing No.	Sheets	Rev	Approved Date	Title
0545- MARK ATEX&IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	No. "X" POSI GRIP MARKING
0547 - ASSY	1 of 1	7	28 Apr 2022	No. "X" Ex de CORROSION GUARD
0547- CG- LS-ASSY	1 of 1	3	28 Apr 2022	No. "X" EXCG LEAD SEAL ASSY
0557-MARK	1 of 1	2	28 Apr 2022	CWe / CXe GLAND MARKING
0559-ASSY	1 of 1	6	28 Apr 2022	No. "X" UNITE <sub>x</sub> -QS GLAND ASSY
0571 - ASSY	1 of 1	6	28 Apr 2022	No. "X" E1EX UNIVERSAL GLAND ASSY
0587-MARK ATEX&IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	No "X" UNITE <sub>x</sub> -F(QS) - MARK
0591-MARK ATEX&IECE <sub>x</sub>	1 of 1	3	28 Apr 2022	No "X" UNITE <sub>x</sub> GLAND MARKING
0595 - 0589 MARKING - ATEX-IECE <sub>x</sub>	1 of 1	2	28 Apr 2022	TMC / TMCX MARLING - ATEX-IECE <sub>x</sub>
0468 ASSY	1 of 1	1	28 Apr 2022	No. "X" A2F-FHC-QS GLAND ASSY.

## Issue 3

Drawing No.	Sheets	Rev	Approved date	Title
0519 - ASSY	1 of 1	7	27 Sept 2023	No. "X" D1EX Ex de CABLE GLANDS
0523 – ASSY-QS	1 of 1	3	27 Sept 2023	No. "X" E1EX QUICK STOP ASSY
0523-ASSY-SL	1 of 1	5	27 Sept 2023	TYPICAL QUICK STOP AND VORTEX SLEEVE ASSEMBLY
0523 – MARK ATEX & IECE <sub>x</sub>	1 of 1	3	27 Sept 2023	No. "X" EX GLAND MARKING
0523-NPT-I	1 of 1	2	27 Sept 2023	No. "X" A2EX, D1EX, A2EX FHC & EXCG INNER
0531 - VRTX	1 of 1	5	27 Sept 2023	No. "X" VRTX GLAND ASSEMBLY
0531-SWA-ASSY	1 of 1	4	27 Sept 2023	No. "X" VRTX – SWA GLAND ASSEMBLY
0547 - ASSY	1 of 1	8	27 Sept 2023	No. "X" Ex de CORROSION GUARD
0554L-ASSY	1 of 1	2	27 Sept 2023	No. "X" UNITE <sub>x</sub> -D COMBINATION GLAND
0560-IS	1 of 1	1	27 Sept 2023	No. "X" E1EX-QS INNER SEAL
0560-VX-IS	1 of 1	-	27 Sept 2023	No. "X" E1EX-VX INNER SEAL
0587-ASSY	1 of 1	6	27 Sept 2023	No. "X" UNITE <sub>x</sub> -F-QS GLAND ASSY.
0589 - ASSY	1 of 1	1	27 Sept 2023	TMCX ASSEMBLY
0589-B	1 of 1	1	27 Sept 2023	TMCX BODY
0589-CN	1 of 1	1	27 Sept 2023	TMCX COUPLING NUT
0589-I	1 of 1	1	27 Sept 2023	TMCX INNER METRIC
0589-I-NPT	1 of 1	1	27 Sept 2023	TMCX INNER NPT
0591-ASSY	1 of 1	5	27 Sept 2023	No. "X" UNITE <sub>x</sub> -E GLAND ASSY
057000-16 - 057010	1 of 1	6	27 Sept 2023	No. "X" CXe GLAND ASSEMBLY