



国家防爆

Certificate number: CNEx21.3386X

Electrical Apparatus for Explosive Atmospheres CERTIFICATE OF CONFORMITY

Manufacturer CCG Cable Terminations (Pty) Ltd
33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa

Product Cable Gland

Type A2EX (VS)(QS)(VX), A2EX-FHC (VS)(QS)(VX)

Marking Ex d IIC Gb/Ex e IIC Gb/Ex tD A21 IP65/IP66/IP67/IP68

Standard(s) —

Drawing No. 0536-ASSY, 0537 - ASSY

The drawings, technical documents and the samples are verified and certified according to standard(s) for safety as below:

GB 3836.1-2010	Explosive atmospheres - Part 1: Equipment - General requirements
GB 3836.2-2010	Explosive atmospheres - Part 2: Equipment protection by flameproof enclosures "d"
GB 3836.3-2010	Explosive atmospheres - Part 3: Equipment protection by increased safety "e"
GB12476.1-2013	Electrical apparatus for use in the presence of combustible dust - Part 1: General requirements
GB12476.5-2013	Electrical apparatus for use in the presence of combustible dust - Part 5: Protection by enclosure "tD"

Note:

See Annex (4 page in total).

Director

Date:

2021-8-30

Valid until:

2026-8-29



CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTER
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Web: www.china-ex.com

Note: This certificate is only valid for products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s). 登录网站 输入数码 查询防伪 2946 1186 1687 2410



国家防爆

Certificate number: CNEx21.3386X

Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Page 1 of 4

This product has been certified, under certificate number IECEx CML 18.0018X, issue 5, dated 2020-09-02 and Test report GB/CML/ExTR20.0189/00 dated 2020-09.

Product Description:

The main material of the product is stainless steel, brass (nickel-plated), etc., and the protection level is IP65/66/67/68 (2m/continuous).

Type designation:

- A2EX (VS)(QS)(VX), A2EX-FHC (VS)(QS)(VX)

Ex Protection & Sizes:

Non-Armoured Cable Glands:

Marking	A2EX (VS)(QS)(VX)	A2EX-FHC (VS)(QS)(VX)
Sizes	00 - 13 (Metric & NPT)	00 - 10 (Metric) 0 - 10 (NPT)
Metric Thread type	16 - 130	16 - 100
NPT thread Type	1/2" - 4"	1/2" - 4"
Sealing Gasket ##	SG	SG
Ex d IIC Gb	YES	YES
Ex e IIC Gb	YES	YES
Ex tD A21	YES	YES
IP 66/68	YES	YES
IP 65 NPT	YES	YES


Note: ##: Not applicable to NPT thread. Applicable to all parallel thread (e.g. Metric). Optional for Ex d application without IP rating.

VS: The VS in the table above indicates that a thin copper/brass disc is fitted between the inner seal and the cone for earth continuity to a metallic cable screen (e.g. variable speed drive cable or a lead sheathed cable). The sealing arrangement between the inner seal and the potted sleeve is not affected. Note that a standard cable gland type can be converted to a (VS) variant by retrofitting the thin copper / brass disc. The product marking does not need to be changed when the copper / brass disc is retrofitted.

Director

Date: 2021-8-30

Valid until: 2026-8-29



CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTER
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Web: www.china-ex.com

Note: This certificate is only valid for products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

Certificate number: CNEx21.3386X

Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Page 2 of 4

QS: The QS in the table above, refers to the Quickstop version of the cable glands. This utilises a clear potting compound to achieve a hard setting seal inside the gland. The sealing compound is transparent and accommodates inspection.

VX: The VX in the table above, refers to the Vortex version of the cable glands. This utilises a coloured potting compound to achieve a hard setting seal inside the gland. There is a transparent elastomeric seal at the end of the compound enclosure to accommodate inspection.

Materials of Cable Gland:

Description	Materials
Metallic Parts	BRASS (Nickel-plated) CZ121, Stainless steel 316, BRONZE PB2, MILD STEEL (EN8), Aluminium 6063
Skid Ring	BRASS (Nickel-plated) CZ121, STAINLESS STEEL 316, BRONZE PB2, MILD STEEL (EN8), Aluminium 6063 HDPE D7255/HL (-100°C to 120°C) or PTFE CCG-PTFE-001(-270°C to 260°C) or Nylon (-65°C to 120°C)
Sealing Compound	Clear Quick Stop Ex Resin S50/EPA (-50°C to 115°C) Coloured Vortex Resin S50/EPA/Y (-50°C to 115°C)
Outer/Inner/Resin Seals End stops	EPDM (64 Shore) (-60°C to 120°C) or Silicone CCG G/65-1R (-70°C to 180°C) or Silicone CCG G/65-1C (-70°C to 180°C)
Sealing Gasket	HDPE D7255/HL (-100°C to 120°C) or PTFE CCG-PTFE-001(-270°C to 260°C) or Nylon (-65°C to 120°C) or RE-FLEx PTFE cord (-268°C to +260°C)

Gland Range Construction

Constructional parts	A2EX (VS) (QS) (VX) ###	A2EX-FHC (VS) (QS) (VX) ###
Inner	A2EX	A2EX
Inner Seal	E1EX	E1EX
Outer Seal	A2	A2
Skid Ring	A2	N/A
Outer nut	A2EX	A2EX-FHC
Cone	A2EX	A2EX
Sealing Compound **	YES	YES
Lock Nut	Optional	Optional
O-Ring	YES	YES
Quick Stop or Vortex with Sleeve Assembly	YES	YES
Coupling/Outer Coupling	N/A	A2EX-FHC

Director

Date:

2021-8-30

Valid until:

2026-8-29



CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTER
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Web: www.china-ex.com

Note: This certificate is only valid for products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Page 3 of 4

** : Use of Metal sleeve and clear sealing compound (Quickstop- QS on Marking), or metal sleeve and coloured sealing compound (Vortex - VX on marking)

: A thin copper/brass disc may be utilised in the (VS) gland variant between the inner seal and the cone for earth continuity to a metallic cable screen (e.g. variable speed drive cable or a lead sheathed cable). The sealing arrangement between the inner seal and the potted sleeve is not affected. Note that a standard cable gland type can be converted to a (VS) variant by retrofitting the thin copper / brass disc. The product marking does not need to be changed when the copper / brass disc is retrofitted.

Detail Size:

Marking Code	A2EX (VS)(QS)(VX)		A2EX-FHC (VS)(QS)(VX)	
	Metric	NPT	Metric	NPT
00s-16ss	M16×1.5	---	M16×1.5	---
00s-20ss	M20×1.5	½" / ¾"	M20×1.5	½" / ¾"
0-20s	M20×1.5	½" / ¾"	M20×1.5	½" / ¾"
1-20	M20×1.5	½" / ¾"	M20×1.5	½" / ¾"
2s-25s	M25×1.5	¾" / 1"	M25×1.5	¾" / 1"
2-25	M25×1.5	¾" / 1"	M25×1.5	¾" / 1"
3s-32s	M32×1.5	1" / 1¼"	M32×1.5	1" / 1¼"
3-32	M32×1.5	1" / 1¼"	M32×1.5	1" / 1¼"
4s-40s	M40×1.5	1¼" / 1½"	M40×1.5	1¼" / 1½"
4-40	M40×1.5	1¼" / 1½"	M40×1.5	1¼" / 1½"
5s-50s	M50×1.5	1½" / 2"	M50×1.5	1½" / 2"
5-50	M50×1.5	1½" / 2"	M50×1.5	1½" / 2"
6s-63s	M63×1.5	2" / 2½"	M63×1.5	2" / 2½"
6-63	M63×1.5	2" / 2½"	M63×1.5	2" / 2½"
7s-75s	M75×1.5	2½" / 3"	M75×1.5	2½" / 3"
7-75	M75×1.5	2½" / 3"	M75×1.5	2½" / 3"
8-80	M80×2.0	3"	M80×2.0	3"
9s-90s	M90×2.0	3" / 3½"	M90×2.0	3" / 3½"
9-90	M90×2.0	3" / 3½"	M90×2.0	3" / 3½"
10-100	M100×2.0	3½" / 4"	M100×2.0	3½" / 4"
11-115	M115×2.0	4"	---	---
12-120	M120×2.0	---	---	---
13-130	M130×2.0	---	---	---

Director

Date: 2021-8-30

Valid until: 2026-8-29



CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTER
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Web: www.china-ex.com

Note: This certificate is only valid for products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

Certificate number: CNEx21.3386X

Electrical Apparatus for Explosive Atmospheres CERTIFICATE OF CONFORMITY

Page 4 of 4

Ex marking: Ex d IIC Gb/ Ex e IIC Gb/ Ex tD A21 IP65/IP66/IP67/IP68

IP degree: IP 66/67/68 (2m/cont) or IP65 (As applicable)

Specific conditions of safety use:

- When the Quickstop or Vortex glands are supplied with the metal sleeve and cementing, they shall be fitted with the metal sleeve and cementing since the internal gland construction only accommodates the large diameter of the metal sleeve for seal clamping.
- The cable glands shall only be used where the temperature, at the point of entry, is between:
Quickstop or Vortex resin, when used with any gaskets/skid rings: (-50°C and +95°C)
EPDM seals & HDPE gaskets/skid rings: (-60°C and +95°C)
EPDM seals & Nylon gaskets/skid rings: (-60°C and +100°C)
Silicone seals & PTFE gaskets/skid rings: (-60°C and +160°C)
- Only the compounds as supplied by the manufacturer shall be used in the glands.
- Cable glands shall only be used on fixed installations where the cable is clamped, or stress applied to the cable in the gland is prevented.
- The appropriate ingress protection level and / or flameproof characteristics must be achieved and maintained at the interface of the gland with the enclosure.

Director

Date:

2021-8-30

Valid until:

2026-8-29



CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTER
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Web: www.china-ex.com

Note: This certificate is only valid for products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).