



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000392

Applicant CCG Cable Terminations (Pty) Ltd
Address 33-37 Forge 3d, Spartan Industrial Area, Kempton Park 1619, South Africa
Manufacturer CCG Cable Terminations (Pty) Ltd
Address 33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa
Production Factory CCG Cable Terminations (Pty) Ltd
Production Address 33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa
Product Non-Armoured Cable Gland
Model/Type A2F, A2F-R, A2F-H, A2F-H-R, A2FX, A2FX-R
Ex marking Ex d IIC Gb, Ex e IIC Gb, Ex d I Mb, Ex e I Mb,
Ex tD A21 IP65/IP66/IP67/IP68
Reference Standards GB3836.1-2010, GB3836.2-2010, GB3836.3-2010, GB12476.1-2013,
GB12476.5-2013

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEC-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (4 pages)

Issued on: 2021-08-23

Valid to: 2026-08-22

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN 0000793



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000392

Page 1 of 4

Product information:

1. This certificate covers the following models:

- A2F, A2F-R, A2F-H, A2F-H-R, A2FX, A2FX-R

Ex Protection & Sizes:

Marking	A2F	A2F - R	A2F-H	A2F-H-R	A2FX	A2FX-R
Sizes	00-13(Metric & NPT)	00-13(Metric & NPT)	00-7(Metric & NPT)	00-7(Metric & NPT)	00-13(Metric & NPT)	00-13(Metric & NPT)
Metric Thread type (M)	16 to 130	16 to 130	16 to 75	16 to 75	16 to 130	16 to 130
NPT thread Type	1/2" to 4"	1/2" to 4"	1/2" to 3"	1/2" to 3"	1/2" to 4"	1/2" to 4"
Sealing Gasket ##	SG	SG	SG	SG	SG	SG
Ex d IIC Gb	YES	YES	YES	YES	YES	YES
Ex e IIC Gb	YES	YES	YES	YES	YES	YES
Ex d I Mb	YES	YES	YES	YES	YES	YES
Ex e I Mb	YES	YES	YES	YES	YES	YES
Ex tD A21	YES	YES	YES	YES	YES	YES
IP 66/68	YES	YES	YES	YES	YES	YES
IP 65 NPT	YES	YES	YES	YES	YES	YES

Note: 1) Intermediate metric thread sizes are permitted. (Cable glands with intermediate metric entry thread sizes shall be constructed by enlarging the entry thread size of the standard size product immediately below the intermediate thread size. The minimum entry wall thickness, allowable number of cores, cable size range and constructional parts utilised (other than the entry thread component) shall not differ from that of the standard size used.)

2) ##: Not applicable to NPT thread. Applicable to all parallel thread (eg Metric). Optional for Ex d application without IP rating.

Issued on: 2021-08-23

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000392

Page 2 of 4

Materials of Non-Armoured Cable Gland:

Description	Materials
Metallic Parts	BRASS (Nickel-plated) CZ121, Stainless steel 316, BRONZE PB2, MILD STEEL (EN8), Aluminium 6063
Skid Ring	BRASS (Nickel-plated) CZ121, STAINLESS STEEL 316, BRONZE PB2, MILD STEEL (EN8), Aluminium 6063 HDPE D7255/HL (-100°C to 120°C) or PTFE CCG-PTFE-001(-270°C to 260°C) or Nylon (-65°C to 120°C)
Outer/Inner Seal	EPDM (64 Shore) (-60°C to 120°C) or Silicone CCG G/65-1R (-70°C to 180°C) or Silicone CCG G/65-1C (-70°C to 180°C)
Sealing gasket	Nylon 66 (-65°C to 120°C) or PTFE CCG-PTFE-001 (-270°C to 260°C) or HDPE D7255/HL (-100°C to 120°C)

Non-Armoured Cable Gland Range Construction:

Constructional parts	A2F	A2F-R	A2F-H	A2F-H-R	A2FX	A2FX-R
Inner	A2F	A2FX-R	A2F	A2F-R	A2F	A2FX-R
Inner Seal	A2	A2	A2	A2	A2	A2
Body	N/A	N/A	N/A	N/A	A2FX	A2FX-R
Outer Seal	N/A	N/A	N/A	N/A	A2	A2
Skid Ring	A2	A2	A2	A2	A2	A2
Outer nut	A2F	A2FX-R	A2FH	A2FH-R	A2F	A2FX-R
Lock Nut	Optional	Optional	Optional	Optional	Optional	Optional

Issued on: 2021-08-23

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



http://www.ccc-cnex.com
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000392

Page 3 of 4

Sealing Gasket ##	SG	SG	SG	SG	SG	SG
-------------------	----	----	----	----	----	----

##: Not applicable to NPT thread. Applicable to all parallel thread (eg Metric). Optional for Ex d application without IP rating.

Detail Size:

Marking Code	A2F, A2F-R, A2FX, A2FX-R		A2F-H, A2F-H-R	
	Metric	NPT	Metric	NPT
00s-16ss	M16×1.5	--	M16×1.5	--
00s-20ss	M20×1.5	½" / ¾"	M20×1.5	½" / ¾"
0-20s	M20×1.5	½" / ¾"	M20×1.5	½" / ¾"
1-20	M20×1.5	½" / ¾"	M20×1.5	½" / ¾"
2s-25s	M25×1.5	¾" / 1"	M25×1.5	¾" / 1"
2-25	M25×1.5	¾" / 1"	M25×1.5	¾" / 1"
3s-32s	M32×1.5	1" / 1¼"	M32×1.5	1" / 1¼"
3-32	M32×1.5	1" / 1¼"	M32×1.5	1" / 1¼"
4s-40s	M40×1.5	1¼" / 1½"	M40×1.5	1¼" / 1½"
4-40	M40×1.5	1¼" / 1½"	M40×1.5	1¼" / 1½"
5s-50s	M50×1.5	1½" / 2"	M50×1.5	1½" / 2"
5-50	M50×1.5	1½" / 2"	M50×1.5	1½" / 2"
6s-63s	M63×1.5	2" / 2½"	M63×1.5	2" / 2½"
6-63	M63×1.5	2" / 2½"	M63×1.5	2" / 2½"
7s-75s	M75×1.5	2½" / 3"	M75×1.5	2½" / 3"
7-75	M75×1.5	2½" / 3"	M75×1.5	2½" / 3"
8-80	M80×2.0	3"	--	--
9s-90s	M90×2.0	3" / 3½"	--	--
9-90	M90×2.0	3" / 3½"	--	--
10-100	M100×2.0	3½" / 4"	--	--
11-110	M110×2.0	4"	--	--
12-120	M120×2.0	--	--	--
13-130	M130×2.0	--	--	--

Ex marking: Ex d IIC Gb, Ex e IIC Gb, Ex d I Mb, Ex e I Mb

Issued on: 2021-08-23

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000392

Page 4 of 4

Ex tD A21 IP65/IP66/IP67/IP68

Note: When manufactured from aluminium, the cable glands shall not be marked for Group I applications.

IP degree: IP66/IP67/IP68(2m cont), IP65 (as applicable)

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

- Service temperature range: $-60^{\circ}\text{C} \sim +100^{\circ}\text{C}$ (standard seals), $-60^{\circ}\text{C} \sim +160^{\circ}\text{C}$ (extreme temp seals).
- The products must be marked with their temperature range, the upper and lower ranges limited by the most onerous of the relevant non-metallic parts and, where applicable, the flameproof testing.
- See instruction for other information.

3. Certificate related report(s):

- Type test report: CQST2102C047
- Factory inspection report: CN2021Q010186

4. Certificate change information: None

Issued on: 2021-08-23

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com