



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000392

Applicant and address

CCG Cable Terminations (Pty) Ltd
33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa

Manufacturer and address

CCG Cable Terminations (Pty) Ltd
33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa

Factory and address

CCG Cable Terminations (Pty) Ltd
33-37 Forge Road, Spartan Industrial Area, Kempton Park 1619, South Africa

Product, series, specification and model

Non-Armoured Cable Gland
A2F, A2F-R, A2F-H, A2F-H-R, A2FX, A2FX-R
Ex db IIC Gb, Ex eb IIC Gb, Ex db I Mb, Ex eb I Mb, Ex ta IIIC Da

Standards


GB/T3836.1-2021, GB/T3836.2-2021, GB/T3836.3-2021, GB/T3836.31-2021

**This product(s) complies with the requirements of CNCA-C23-01: 2019
China Compulsory Certification Implementation Rule on Explosion
Protected Electrical Product.**

Issue date: 2026-08-21 Valid to: 2031-08-22

Detailed information and status of this certificate is available by using the QR code,
visiting CNEx's website or CNCA's website: www.cnca.gov.cn.

This translated document has no legal effect and shall not be used alone.



Director:

Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000392

Annex: Page 1 of 5

Product information:

1. This certificate covers the following models:

- A2F, A2F-R, A2F-H, A2F-H-R, A2FX, A2FX-R

Ex Protection & Sizes:

Marking	A2F	A2F-R	A2F-H	A2F-H-R	A2FX	A2FX-R
Sizes	00-13 (Metric& NPT)	00-13 (Metric& NPT)	00-7 (Metric &NPT)	00-7 (Metric& NPT)	00-13 (Metric& NPT)	00-13 (Metric& NPT)
Metric Thread type (M)	16 to 130	16 to 130	16 to 75	16 to 75	16 to 130	16 to 130
NPT thread Type	1/2" to 4"	1/2" to 4"	1/2" to 3"	1/2" to 3"	1/2" to 4"	1/2" to 4"
Sealing Gasket ##	SG	SG	SG	SG	SG	SG
Ex db IIC Gb	YES	YES	YES	YES	YES	YES
Ex eb IIC Gb	YES	YES	YES	YES	YES	YES
Ex db I Mb	YES	YES	YES	YES	YES	YES
Ex eb I Mb	YES	YES	YES	YES	YES	YES
Ex ta IIIC Da	YES	YES	YES	YES	YES	YES
IP 66/68	YES	YES	YES	YES	YES	YES
IP 65 NPT	YES	YES	YES	YES	YES	YES



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000392

Annex: Page 2 of 5

Note: 1) Intermediate metric thread sizes are permitted. (Cable glands with intermediate metric entry thread sizes shall be constructed by enlarging the entry thread size of the standard size product immediately below the intermediate thread size. The minimum entry wall thickness, allowable number of cores, cable size range and constructional parts utilised (other than the entry thread component) shall not differ from that of the standard size used.)

2) ##: Not applicable to NPT thread. Applicable to all parallel thread (eg Metric). Optional for Ex db application without IP rating.

Materials of Non-Armoured Cable Gland:

Description	Materials
Metallic Parts	BRASS (Nickel-plated) CZ121, Stainless steel 316, BRONZE PB2, MILD STEEL (EN8), Aluminium 6063
Skid Ring	BRASS (Nickel-plated) CZ121, STAINLESS STEEL 316, BRONZE PB2, MILD STEEL (EN8), Aluminium 6063 HDPE D7255/HL (-100°C to 120°C) or PTFE CCG-PTFE-001(-270°C to 260°C) or Nylon (-65°C to 120°C)
Outer/Inner Seal	EPDM (64 Shore) (-60°C to 120°C) or Silicone CCG G/65-1R (-70°C to 180°C) or Silicone CCG G/65-1C (-70°C to 180°C)
Sealing gasket	Nylon 66 (-65°C to 120°C) or PTFE CCG-PTFE-001 (-270°C to 260°C) or HDPE D7255/HL (-100°C to 120°C)

Non-Armoured Cable Gland Range Construction:

Constructional parts	A2F	A2F-R	A2F-H	A2F-H-R	A2FX	A2FX-R
----------------------	-----	-------	-------	---------	------	--------



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000392

Annex: Page 3 of 5

Inner	A2F	A2FX-R	A2F	A2F-R	A2F	A2FX-R
Inner Seal	A2	A2	A2	A2	A2	A2
Body	N/A	N/A	N/A	N/A	A2FX	A2FX-R
Outer Seal	N/A	N/A	N/A	N/A	A2	A2
Skid Ring	A2	A2	A2	A2	A2	A2
Outer nut	A2F	A2FX-R	A2FH	A2FH-R	A2F	A2FX-R
Lock Nut	Optional	Optional	Optiona 	Optiona 	Optiona 	Optiona
Sealing Gasket ##	SG	SG	SG	SG	SG	SG

##: Not applicable to NPT thread. Applicable to all parallel thread (eg Metric).
Optional for Ex db application without IP rating.

Detail Size:

Marking Code	A2F, A2F-R, A2FX, A2FX-R		A2F-H, A2F-H-R	
	Metric	NPT	Metric	NPT
00s-16ss	M16×1.5	--	M16×1.5	--
00s-20ss	M20×1.5	1/2" / 3/4"	M20×1.5	1/2" / 3/4"
0-20s	M20×1.5	1/2" / 3/4"	M20×1.5	1/2" / 3/4"
1-20	M20×1.5	1/2" / 3/4"	M20×1.5	1/2" / 3/4"
2s-25s	M25×1.5	3/4" / 1"	M25×1.5	3/4" / 1"
2-25	M25×1.5	3/4" / 1"	M25×1.5	3/4" / 1"
3s-32s	M32×1.5	1" / 1 1/4"	M32×1.5	1" / 1 1/4"
3-32	M32×1.5	1" / 1 1/4"	M32×1.5	1" / 1 1/4"
4s-40s	M40×1.5	1 1/4" / 1 1/2"	M40×1.5	1 1/4" / 1 1/2"



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000392

Annex: Page 4 of 5

4-40	M40×1.5	1¼" / 1½"	M40×1.5	1¼" / 1½"
5s-50s	M50×1.5	1½" / 2"	M50×1.5	1½" / 2"
5-50	M50×1.5	1½" / 2"	M50×1.5	1½" / 2"
6s-63s	M63×1.5	2" / 2½"	M63×1.5	2" / 2½"
6-63	M63×1.5	2" / 2½"	M63×1.5	2" / 2½"
7s-75s	M75×1.5	2½" / 3"	M75×1.5	2½" / 3"
7-75	M75×1.5	2½" / 3"	M75×1.5	2½" / 3"
8-80	M80×2.0	3"	--	--
9s-90s	M90×2.0	3" / 3½"	--	--
9-90	M90×2.0	3" / 3½"	--	--
10-100	M100×2.0	3½" / 4"	--	--
11-110	M110×2.0	4"	--	--
12-120	M120×2.0	--	--	--
13-130	M130×2.0	--	--	--

Ingress protection: IP66/IP67/IP68(2m cont), IP65 (as applicable)

Ex marking: Ex db IIC Gb, Ex eb IIC Gb, Ex db I Mb, Ex eb I Mb,

Ex ta IIIC Da

Note: When manufactured from aluminium, the cable glands shall not be marked for Group I applications.

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of use:

- Service temperature range: -60°C~+100°C(standard seals),



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000392

Annex: Page 5 of 5

-60°C~+160°C(extreme temp seals).

- The products must be marked with their temperature range, the upper and lower ranges limited by the most onerous of the relevant non-metallic parts and, where applicable, the flameproof testing.
- See instruction for other information.

3. Certificate change information:

- This certificate is issued for renewal upon expiration. The first issuance date of the certificate is: August 23, 2021.



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.

