



Mining And Surface Certification (Pty) Ltd

2015/021934/07

THIS CERTIFICATE IS ISSUED AS AN I.A. CERTIFICATE IN TERMS OF THE MINE HEALTH AND SAFETY ACT, ACT NO 29 OF 1996 (AND REGULATIONS), THE OCCUPATIONAL HEALTH AND SAFETY ACT (ACT 85 OF 1993) AND REGULATION 17 OF THE ELECTRICAL MACHINERY REGULATIONS

IA CERTIFICATE	MASC MS/22-9001	Y	Issue		2				
		^		1010	_				
Issue Date	15 May 2025	- · ·	Expiry D		01 June 2032				
** Based on Certificate No	IECEx CML 18.001	-	Issue / Variations / Amendment 9						
Requested by	CCG Cable Termination (Pty) Ltd								
	33-37 Forge Road,	3-37 Forge Road, Spartan Industrial Area, Kempton Park, 1619, South Africa							
Manufacturer	CCG Cable Termination (Pty) Ltd								
	33-37 Forge Road,	-37 Forge Road, Spartan Industrial Area, Kempton Park, 1619, South Africa							
Description	Cable glands for use with armoured cables, Types:								
	E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe,								
	EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal,								
	UNITEX-D (VS), UNITEX-E, UNITEX-QS (VX), UNITEX-F, UNITEX-F-QS(VX), TMCX.								
	3.11.2x 3 (10), 3.11.2x 2, 3.11.2x 23 (17), 3.11.2x 1 (20)								
	Cable glands for use with non-armoured and braid cables, Types:								
	FLP-TR (QS)(VX), FLP-TR-R ,FLP-TR- KHDE (QS)(VX), FLPHOSE (QS)(VX), FLP-H-R, VRTX.								
	1 - 11 (Q3)(VX), 1 L1 - 11 - 11 - 11 - 11 - 11 - 11 - 1								
	Refer to Annex B below for more details.								
Equipment	Cable Gland Series		Туре	As ab	ove / below				
MARKING:	Type:	Refer to des							
Original marking as per	Ex Marking:	Ex db I Mb			Ex eb IIC Gb				
certificate ** remains	Ex maning.	Ex db IIC G			Ex nR IIC Gc				
applicable.		Ex eb I Mb	9		Ex ta IIIC Da				
IA number must be added.		IP 66/67/68 (2m) or IP65 (As applicable)							
in than bot made bo daded.		` ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' ' '							
"SANS 808" to be added on	SANS 808 (On relevant glands)								
	IA Number:	MASC MS/22-9001X (To be additionally marked on equipment)							
relevant glands	Warnings:	See Base Certificate ** (original marking must be applied)							
Quality Assurance report (QAR) / Notification		ZA/ICS/QAR14.0001/10							
(QAN) Expiry date:									

Compliance:

The equipment as described above has been allocated the rating <u>Explosion Protected 'as above'</u> utilizing the SANS/IEC Standards:

For the full range of glands:

- SANS (IEC) 60079-0: 2019 (2017) Electrical equipment for explosive gas atmospheres Part 0: General Equipment
- SANS (IEC) 60079-1: 2015 (2014) Explosive atmospheres Part 1: Equipment protection by flameproof enclosures "d"
- SANS (IEC) 60079-7: 2019 (2017) Explosive atmospheres Part 7: Equipment protection by increased safety "e"
- SANS (IEC) 60079-15: 2022 (2017) Explosive atmospheres Part 15: Equipment protection by type of protection "n"
- SANS (IEC) 60079-31:2014 (2013) Explosive atmospheres Part 31: Equipment dust ignition protection by enclosure "t"
- SANS (IEC) 60529: 2013 "Degrees of protection provided by enclosures (IP Code)"

In addition; only for Armortex, FLP, FLP Hose, FLP-H-R, FLP TR, FLP-TR-R, FLP-TR-KHDE (ZA/ICS/ExTR25.0005/00):

• SANS 808: 2024: "Cable glands for use on Group I flameproof equipment (Ex d)"

Note: This certificate covers only the listed standards and does not imply compliance to any other standard, related or inferred. It is up to the manufacturer to ensure that the product complies to all relevant standards for the application.

Special conditions of safe use "X":

Refer to Annex A below for more details.

Conditions of manufacture:

Refer to Annex A below for more details.

Terine Orsmond PROJECT MANAGER

Regardt Zeelie TECHNICAL SPECIALIST

This certificate covers all units sold as long as the QAR/QAN remains valid.

According to the relevant requirements of the MHS Act and the OHS Act, production units of explosion protected equipment are required to comply with third party quality assurance (an approved mark scheme or batch testing by an accredited test laboratory).

Page 1 of 5

Apparatus in hazardous locations is subject to the following provisions as applicable, which shall be adhered to:

SANS 10086 requirements;

Any conditions mentioned in the above certificate;

Any relevant requirements of the MHS Act;

Any restrictions and conditions enforced by the chief inspector of mines, principal inspector (Group I equipment) or chief inspector of factories (Group II equipment).

This certificate may only be reproduced in full
The certificate is not transferable and remains the property of the issuing body.

IA CERTIFICATE: MASC MS/22-9001X (Rev 2)

Equipment: Cable Gland Series - Various

(Expiry date: 01 June 2032)

Page 2 of 5

ANNEX A

This do	cument is based on and must be read in conjunction with certificate IECEx CML 18.0018X Issue 9
	Description (According to Base Certificate) **
Refer to Annex B belo	
"Pofor to description in	n Base Certificate ** (and any applicable schedules/issues/variations)."
Refer to description i	Original:
	New issue of certificate based on Base Certificate **. Replaces MASC MS/13-028X.
Sef	Rev 1:
Summary of revisions:	Updated to IECEx CML 18.0018X Issue 8.
	Rev 2:
	Addition of new or revised cable glands.
Standard	Update to latest SANS 808 standard. See Base Certificate **
compliance	
Special conditions of safe use ("X")	 General Conditions The cable glands shall only be used where the temperature, at the point of entry, is between: Quickstop or Vortex resin type S50 / EPA, when used with any gaskets/skid rings: (-50°C and +95°C) Quickstop or Vortex resin type FR/846, when used with EPDM seals & Nylon gaskets/skid rings or Silicone seals & PTFE gaskets / skid rings: (-60°C and +100°C)
	 EPDM seals & HDPE gaskets/skid rings: (-60°C and +95°C) EPDM seals & Nylon gaskets/skid rings: (-60°C and +100°C) Silicone seals & PTFE gaskets/skid rings:
	 (-60°C and +160°C) The corrosion guard is not an essential part of the explosion protection. The corrosion guard material has a Relative Temperature Index (RTI) of 120°C.
	 ii. Cable glands for unarmoured or braided cable and approved only for Group IIC/IIIC (Not barrier glands or Group I) shall only be used on fixed installations where the cable is clamped, or stress applied to the cable in the gland is prevented. iii. When constructed of aluminium, the glands shall not be used in Group I applications. iv. When the RE-FLEx sealing method is used, the gland installer shall refer to the manufacturer's instructions.
	Conditions for Specific Glands i. VRTX range of glands: • The VRTX range of cable glands shall only be used on fixed installations where the cable is clamped, or stress applied to the cable in the gland is prevented. ii. Armortex and E1EX-U type ranges of glands • The Armortex and E1EX-U type glands have been tested for braided cable for Group II and III only. When braided cable is fitted, they shall only be used on fixed installations where the cable is clamped or stress applied to the cable in the gland is prevented. (Does not apply to barrier gland versions.)
Conditions of manufacture	The following conditions are required of the manufacturing process for compliance with the certification. i. Where the product incorporates certified parts or safety critical components, the manufacturer of the product defined on this certificate shall continually monitor these parts/components for any modifications introduced by the manufacturer(s) of these constituent parts. If the manufacturer of any constituent part introduces any changes which affect the compliance of the certified product that is the subject of this certificate, the manufacturer is required to have this certificate updated. ii. Cable glands with intermediate metric entry thread sizes shall be constructed by enlarging the entry thread size of the standard size product immediately below the intermediate thread size. The minimum entry wall thickness, allowable number of cores, cable size range and constructional parts utilised (other than the entry thread component) shall not differ from that of the standard size used. iii. When constructed of aluminium, the glands shall not be marked for Group I applications.
Conditions of Certification	 This Certificate covers all units sold from the date of this approval and covered by a valid QAR and/or South African Markscheme / Batch testing. The apparatus must be additionally marked with the MASC marking details above. This approval only covers the equipment as certified above and does not include any scheduled additions or variations / amendments / new issues to the certificate(s), made after the above date. The equipment does not need to be re-tested when used on the conditions and with such restrictions as prescribed by the certificate on which this IA Certificate is based and any other conditions in this IA Certificate.

IA CERTIFICATE: MASC MS/22-9001X (Rev 2) Equipment: Cable Gland Series - Various

(Expiry date: 01 June 2032)

Page 3 of 5

	 The certification on which this IA Certificate is based must remain valid. The extent of the requirements in the ARP 0108 (or regulations), SANS 10108 and any other applicable regulations on the certification of the equipment must remain unchanged. The Ex quality assurance notification/report for the equipment must remain valid.
Conclusion:	 From the above and the selective examination of the documentation, nothing contrary to the requirements of the applicable standards was found, provided that the equipment / component is used as described in the above document / certificate and according to the MASC conditions below. A MASC IA certificate is issued based on the work done as per the Base Certificate **. The routine tests for production units according to the Base Certificate ** must be complied with (if applicable).

This document is issued based on Mining And Surface Certification's Standard Contract terms and conditions available on request.

While every endeavour is made to ensure that a test / assessment / inspection is representative and accurately performed, and that a report / certificate is accurate in the quoted results and conclusions drawn from the test / assessment / inspection, MASC or its directors/employees shall in no way be liable for any error made in carrying out the test / assessment or for any erroneous statement, whether in fact or in opinion, contained in a report / certificate issued pursuant to a test / assessment / inspection.

MASC takes no responsibility for any non-conformances, exclusions or any results / assessments / inspections not in compliance with the standards. By marking the equipment in accordance with the documentation / standard, the manufacturer / applicant attests on his own responsibility that the equipment / installation has been designed and constructed in accordance with the applicable requirements of the relevant standards and documentation, that the routine verifications / routine tests have been correctly completed and the equipment / installation complies with the documentation and standard(s).

This document is only for use and application in South Africa. It is issued based on National interpretations and accepted practices.

IA CERTIFICATE: MASC MS/22-9001X (Rev 2) Equipment: Cable Gland Series - Various

Equipment: Cable Gland Series - Va (Expiry date: 01 June 2032)

Page 4 of 5

Annex B - Description

Cable glands for use with armoured cables, Types:

E1EX (VS)(QS)(VX), E1EX-U (VS)(QS)(VX), E1EX Lead Seal, D1EX (QS)(VX), CXe, CWe, EXCG (VS)(QS)(VX), VRTX SWA, FLP (QS)(VX), ARMORTEX (QS)(VX), EXCG-Lead Seal, UNITEx-D (VS), UNITEx-E, UNITEx-QS (VX), UNITEx-F, UNITEx-F-QS(VX), TMC, TMCX.

Cable glands for use with non-armoured and braid cables, Types; FLP-TR (QS)(VX), FLP-TR-R, FLP-TR-KHDE (QS)(VX), FLP-H-R, VRTX.

Product	Sizes	Ex db IIC Gb	Ex eb IIC Gb	Ex db I Mb	Ex eb I Mb	Ex nR IIC Gb	Ex ta IIIC Da
ARMORTEX (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓	✓
E1EX U (VS)(QS)(VX)	00-10 (Metric & NPT)	✓	✓	✓	✓	✓	✓
FLP (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓	✓
FLP Hose (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓	✓
FLP-H-R	00-7 (Metric & NPT)	✓	✓	✓	✓	✓	✓
FLP TR (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓	✓
FLP-TR-R	00-7 (Metric & NPT)	✓	✓	✓	✓	✓	✓
FLP-TR-KHDE (QS)(VX)	00-7 (Metric & NPT)	✓	✓	✓	✓	✓	✓
D1EX (QS)(VX)	00-13 (Metric) 00-11 (NPT)	✓	✓			✓	✓
E1EX (VS)(QS)(VX)	00-13 (Metric) 00-11 (NPT)	✓	✓			✓	✓
E1EX Lead Seal	00-13 (Metric) 00-11 (NPT)	✓	✓			✓	✓
EXCG (VS)(QS)(VX)	00-10 (Metric)	✓	✓			✓	✓
EXCG – Lead Seal	00-13 (Metric)	✓	✓			✓	✓
UNITEx-D (VS)	00-10 (Metric & NPT)	✓	✓			✓	✓
UNITEx ~QS(VX)	00-10 (Metric & NPT)	✓	✓			✓	✓
UNITEx-F~ QS(VX)	00-10 (Metric & NPT)	~	~			✓	✓
TMCX	00-11 (Metric & NPT)	~	~			✓	✓
TMC	00-11 (Metric & NPT)		✓			✓	✓
UNITEx-E	00-10 (Metric & NPT)		✓			✓	✓
UNITEx-F	00-10 (Metric & NPT)		✓			✓	✓
CXE	00-13 (Metric) 00-11 (NPT)		✓				✓
CWE	00-13 (Metric) 00-11 (NPT)		✓				✓
VRTX	0-8 (Metric)		✓				✓
VRTX SWA	0-8 (Metric)		✓				✓

Notes

- Cable glands with parallel entry threads are IP66/68 when fitted with the supplied sealing gasket. NPT threads are at least IP65 as standard, but IP68 (2m) can be achieved if one of the following grease types is applied to the NPT thread before fitting: - Renolit Lubrene CA 700, Renolit LC-WP2, Renolit Lubrene LX 220 EP2, Renolit Moly LX 2 or Dow Corning 4 Electrical Compound.
- 2. Cable glands with parallel entry threads (e.g. Metric and BSP parallel) are supplied with fitted sealing gaskets as standard. The sealing gasket is optional for Ex d applications without IP rating. (RE-FLEx cord may be used as an alternative to a standard sealing gasket.)
- 3. 'VS' in the name of a cable gland variant indicates that a thin copper/brass disc is fitted between the inner seal and the cone for earth continuality to a metallic cable screen (e.g. variable speed drive cable or a lead sheathed cable). The sealing arrangement between the inner seal and the potted sleeve is not affected. Note that a standard cable gland type can be

IA CERTIFICATE: MASC MS/22-9001X (Rev 2) Equipment: Cable Gland Series - Various

(Expiry date: 01 June 2032)

Page 5 of 5

- converted to a (VS) variant by retrofitting the thin copper / brass disc. The product marking does not need to be changed when the copper / brass disc is retrofitted.
- 4. '-FC' in the name of a cable gland variant indicates that the outer seal nut has an additional female thread to allow the connection of a flexible conduit.
- 5. 'QS' in the name of a cable gland variant, indicates that it is the Quickstop resin barrier version of the cable gland. This utilises a clear potting compound to achieve a hard setting seal inside the gland. The sealing compound is transparent and accommodates inspection.
- 6. 'VX' in the name of a cable gland variant, refers to the Vortex resin barrier version of the cable gland. This utilises a coloured potting compound to achieve a hard setting seal inside the gland. There is a transparent elastomeric seal at the end of the compound enclosure to accommodate inspection.
- 7. Cable glands that are available as both barrier (QS or VX) and non-barrier versions may be supplied as non-barrier versions together with the additional components needed to convert them to barrier versions if required. When the conversion is carried out the product marking does not need to be changed
- 8. RE-FLEx sealing cord can be used with any suitably certified cable gland, adaptor, reducer, plug, etc.as an alternative to a standard sealing gasket to achieve IP66/68. It is intended as a retro-fit solution and must be installed according to the fitting instructions supplied with it.

Materials of Manufacture

- Brass (CZ121), Bronze (PB2), Stainless Steel (316), Aluminium (6063), Mild steel (EN8)
- HDPE (D7255/HL), PTFE (CCG PTFE-001), Nylon (6)
- EPDM (64 Shore), Silicone (CCG G/65-1C)
- QuickStop Ex resin (S50/EPA or FR/846), VORTEx Ex resin (S50/Y, EPA/Y or FR/846/Y)

Components covered by Ex Certificates issued to older editions of Standards None