



شهادة مطابقة CERTIFICATE OF CONFORMITY

Certificate Number:	25-07-155984/E25-07-162444/NB0007	رقم الشهادة:
Registration Date:	03/07/2025	تاريخ التسجيل:
Valid Until:	02/07/2028	صالحة لغاية:
Issued To:	CCG CABLE TERMINATIONS (PTY) LTD P.O. Box 192 ,Spartan Industrial Township Kempton Park Forge Road ,SOUTH AFRICA	أصدرت إلى :
Sector:	Electrical	قطاع: كهرباء
Product Category:	ECAS-Ex	تصنيف المنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار
Product Sub-Category:	ECAS-Ex	التصنيف الفرعي للمنتج: الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Please check Schedule of certification for all product details يرجى التحقق من بيان التسجيل المرفق لجميع تفاصيل المنتجات



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



Products are registered under the Emirates Conformity Assessment Scheme (ECAS) based on compliance to the Approved Standards المنتجات مسجلة في نظام تقويم المطابقة الإماراتي (إيكاس) بناء على مطابقتها للمواصفات المعتمدة

600565554

www.moiat.gov.ae

@MoIAT



تم إصدار هذا المستند إلكترونياً ولا يحتاج إلى ختم أو توقيع.
This document has been issued electronically and doesn't require a stamp and signature.



بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

Company Name: CCG CABLE TERMINATIONS (PTY) LTD **اسم الشركة:**

Product Category: ECAS-Ex **تصنيف المنتج:** الأجهزة الكهربائية المعدة للاستخدام في الأجواء القابلة للانفجار

Certificate No.: 25-07-155984/E25-07-162444/NB0007 **رقم التسجيل:**

Registration Date: 03/07/2025 **تاريخ التسجيل:**

Valid Until: 02/07/2028 **صالح لغاية:**

Sr.No.	الاسم التجاري Brand Name	رقم الموديل Model Number	تفاصيل المنتج Product Details	تصنيف النجوم Star Rating	الأبعاد/الحجم Dimension/Size	التقارير Reports	المواصفات المطبقة Applicable Standards	بلد المنشأ Country Of Origin
1	CCG	BD****D	Breather/drain; Type of Protection: Ex db and Ex tb ; Marking: BD***D, Ex db IIC Gb, Ex db I Mb, Ex tb III C Db, IP6X 'dust-tight'; Temp: -60°C to +95°C	N/A	NA	IECEX CML 16.0021X GB/CML/ExTR16.0130/00 GB/CML/ExTR20.0004/00 GB/CML/ExTR20.0271/00 GB/CML/ExTR16.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	SOUTH AFRICA
2	CCG	BD***E	Breather/drain; Type of Protection: Ex eb and Ex tb ;	N/A	NA	IECEX CML 16.0021X GB/CML/ExTR16.0130/00 GB/CML/ExTR20.0004/00	UAE.S IEC 60079-0,	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Marking: BD***E, Ex eb IIC Gb, Ex eb I Mb, Ex tb III C Db, IP66; Temp: -60°C to +95°C(HDPE gasket), -60°C to +100°C(Nylon gasket), -60°C to +160°C(PTFE gasket)			GB/CML/ExTR20.0271/00 GB/CML/ExTR16.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	
3	CCG	BA***E	Breather Drainer Adapter; Type of Protection: Ex eb and Ex tb ; Marking: BA***E, Ex eb IIC Gb, Ex eb I Mb, Ex tb III C Db, IP66; Temp: -60°C to +95°C(HDPE gasket), -60°C to +100°C(Nylon gasket), -60°C to +160°C(PTFE gasket)	N/A	NA	IECEX CML 16.0021X GB/CML/ExTR16.0130/00 GB/CML/ExTR20.0004/00 GB/CML/ExTR20.0271/00 GB/CML/ExTR16.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	SOUTH AFRICA
4	CCG	E1EX (VS)(QS)(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIC D, Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
5	CCG	E1EX-U (VS)(QS) (VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIC D, Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
6	CCG	E1EX Lead Seal	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00	UAE.S IEC 60079-0, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			"eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
7	CCG	D1EX (QS)(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

8	CCG	CXe	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
9	CCG	CWe	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			IP65 (As applicable); For temperature details refer IECEx CML 18.0018X				IEC 60079-31	
10	CCG	EXCG (VS)(QS)(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
11	CCG	VRTX SWA	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Gc, Ex ta IIIC D, Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	IEC 60079-15, UAE.S IEC 60079-31	
12	CCG	FLP (QS)(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D, Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
13	CCG	FLP-TR-R	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR",	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1,	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
14	CCG	ARMORTEX (QS) (VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
15	CCG	EXCG-Lead Seal	Cable Gland Series; Type of Protection:	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00	UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
16	CCG	FLP-TR (QS)(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			details refer IECEx CML 18.0018X					
17	CCG	FLP-TR-KHDE (QS) (VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
18	CCG	FLPHOSE (QS)(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15,	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X				UAE.S IEC 60079-31	
19	CCG	FLP-H-R	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
20	CCG	VRTX	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIC D, Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
21	CCG	UNITEx-D (VS)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIC D, Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
22	CCG	UNITEx-E	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00	UAE.S IEC 60079-0, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			"eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
23	CCG	UNITEx~QS(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEx CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology



بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

24	CCG	UNITEx-F	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
25	CCG	UNITEx F~QS(VX)	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex"ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			IP65 (As applicable); For temperature details refer IECEx CML 18.0018X				IEC 60079-31	
26	CCG	TMC	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC D,Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00 GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
27	CCG	TMCX	Cable Gland Series; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking:Ex db IIC Gb, Ex eb I Mb, Ex eb IIC Gb, Ex nR IIC	N/A	NA	IECEX CML 18.0018X GB/CML/ExTR21.0087/00 GB/CML/ExTR18.0020/00 GB/CML/ExTR20.0189/00 GB/CML/ExTR19.0094/00 GB/CML/ExTR18.0269/00 GB/CML/ExTR23.0221/00 GB/CML/ExTR20.0126/00 GB/CML/ExTR25.0041/00 GB/CML/ExTR19.0171/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Gc, Ex ta IIIC D, Refer to description IP 66/67/68 (2m) or IP65 (As applicable); For temperature details refer IECEx CML 18.0018X			GB/CML/ExTR22.0046/00 ZA/ICS/QAR14.0001/10	IEC 60079-15, UAE.S IEC 60079-31	
28	CCG	AGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous)	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			(Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
29	CCG	AGZZZGYYYE - IE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
30	CCG	RGZZZGYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			"eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X				IEC 60079-31	
31	CCG	UGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel	N/A	NA	IECEX TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7,	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X				UAE.S IEC 60079-15, UAE.S IEC 60079-31	
32	CCG	CGZZZGYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00	UAE.S IEC 60079-0, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

		Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X		GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
--	--	---	--	---	--	--



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

33	CCG	AGZZZGYYE - INSA	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking	N/A	NA	IECEX TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
----	-----	------------------	--	-----	----	---	---	--------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			plugs ; For temperature details refer IECEx TSA 23.0024X					
34	CCG	PAGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers,	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
35	CCG	AELBGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIC Da, IP65/66/67/68	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			(2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
36	CCG	ATGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
37	CCG	AYGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db",	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X				IEC 60079-31	
38	CCG	SAGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X				60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
39	CCG	SCGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking	N/A	NA	IECEX TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00	UAE.S IEC 60079-0,	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

		Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details		GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31
--	--	---	--	--	---



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			refer IECEx TSA 23.0024X					
40	CCG	SELBGZZZGYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs,	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
41	CCG	S45GZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
42	CCG	SBAGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, **	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
43	CCG	SBCGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
44	CCG	SBELBGZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45°	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X				IEC 60079-15, UAE.S IEC 60079-31	
45	CCG	SB45GZZZGYYYE	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable	N/A	NA	IECEX TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00	UAE.S IEC 60079-0, UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

		<p>Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non- metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X</p>	<p>GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10</p>	<p>60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31</p>
--	--	--	---	---



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

46	CCG	PFGZZZER	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking	N/A	NA	IECEX TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
----	-----	----------	---	-----	----	---	---	--------------



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			plugs ; For temperature details refer IECEx TSA 23.0024X					
47	CCG	3527ZZZ	Threaded Adaptors, Reducers, Unions, Couplers, Blanking Plugs, Insulated Adaptors, Adjustable Elbow / 'T' / 'Y' Adaptors, Swivel Adaptors, Swivel Couplers and Swivel Elbow / 45° Adaptors; Type of Protection: Flameproof Ex "db", Increased Safety Ex "eb", *Restricted Breathing Ex "nR", Dust Ignition Ex "ta"; Marking: ** Ex db IIC Gb, ** Ex db I Mb, Ex eb IIC Gb, ** Ex eb I Mb, *Ex nR IIC Gc, Ex ta IIIC Da, IP65/66/67/68 (2m continuous) (Refer to Annex for service temperature range) * Threaded Adaptors, Reducers,	N/A	NA	IECEx TSA 23.0024X GB/CML/ExTR16.0080/00 GB/CML/ExTR16.0130/00 GB/CML/ExTR23.0055/00 GB/CML/ExTR20.0053/00 GB/CML/ExTR22.0136/00 GB/CML/ExTR19.0166/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Unions, Couplers, Blanking Plugs, Insulated Adaptors ** Not the non-metallic blanking plugs ; For temperature details refer IECEx TSA 23.0024X					
48	CCG	PosiFit ' X '	PosiFit Junction boxes; Type of Protection: Increased Safety "eb", "ec", Dust Ignition "tb", "tc"; Marking: Ex eb I Mb, Ex eb IIC T6 Gb, Ex tb IIC T70°C Db, Ex ec IIC T6 Gc, Ex tc IIC T70°C Dc, IP66/IP67/IP68 (2m cont.); Ta = -60°C to +40°C/55°C	N/A	NA	IECEx MSC 20.0003X GB/CML/ExTR16.0132/00 GB/CML/ExTR15.0072/00 AU/MS/ExTR20.0005/00 GB/CML/ExTR19.0225/00 GB/CML/ExTR17.0138/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-7, UAE.S IEC 60079-31	SOUTH AFRICA
49	CCG	A2F	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026				IEC 60079-15, UAE.S IEC 60079-31	
50	CCG	A2F-R	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
51	CCG	A2F-H	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026				60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
52	CCG	A2F-H-R	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
53	CCG	A2FX	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1,	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			"eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026				UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
54	CCG	A2FX-R	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
55	CCG	A2FX-H	Cable glands for use with unarmoured cables; Type of Protection:	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00	UAE.S IEC 60079-0, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026			GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
56	CCG	A2FX-H-R	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
57	CCG	A2F-HTF	Cable glands for use with unarmoured	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00	UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026			GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	
58	CCG	A2F-FHC	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

59	CCG	A2F FHC~QS(VX)	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEX TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
60	CCG	A2F-VX	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details	N/A	NA	IECEX TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			refer IECEx TSA 23.0026					
61	CCG	A2F-F-VX	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
62	CCG	VARITEx-D	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			nR IIC Gc; For temperature details refer IECEx TSA 23.0026				IEC 60079-31	
63	CCG	VARITEx-D-VX	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
64	CCG	Posi Grip (VS)	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb,	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026				60079-15, UAE.S IEC 60079-31	
65	CCG	Posi Grip~QS(VX) (VS)	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
66	CCG	A2EX (VS)(QS)(VX)	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta";	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7,	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION

Ministry of Industry and Advanced Technology

			Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026				UAE.S IEC 60079-15, UAE.S IEC 60079-31	
67	CCG	A2EX-FHC (VS) (QS)(VX)	Cable glands for use with unarmoured cables; Type of Protection: Flameproof "db", Increased Safety "eb", Restricted Breathing "nR", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, Ex nR IIC Gc; For temperature details refer IECEx TSA 23.0026	N/A	NA	IECEx TSA 23.0026 GB/CML/ExTR20.0022/00 GB/CML/ExTR20.0121/00 GB/CML/ExTR23.0228/00 GB/CML/ExTR22.0085/00 ZA/ICS/QAR14.0001/10	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-15, UAE.S IEC 60079-31	SOUTH AFRICA
68	CCG	Fixed 90°	Adaptors; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta"; Marking: Ex db IIC Gb, Ex eb IIC	N/A	NA	ZA/ICS/QAR14.0001/10 IECEx TSA 23.0023U GB/CML/ExTR18.0203/00 GB/CML/ExTR16.0131/00 GB/CML/ExTR16.0073/00 GB/CML/ExTR22.0143/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل SCHEDULE OF CERTIFICATION Ministry of Industry and Advanced Technology

			Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, IP65 / IP66 / IP67 / IP68 - refer to Schedule of Limitations; For temperature details refer IECEx TSA 23.0023U				IEC 60079-7, UAE.S IEC 60079-31	
69	CCG	Fixed T	Adaptors; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta" ; Marking: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, IP65 / IP66 / IP67 / IP68 - refer to Schedule of Limitations; For temperature details refer IECEx TSA 23.0023U	N/A	NA	ZA/ICS/QAR14.0001/10 IECEX TSA 23.0023U GB/CML/ExTR18.0203/00 GB/CML/ExTR16.0131/00 GB/CML/ExTR16.0073/00 GB/CML/ExTR22.0143/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S IEC 60079-7, UAE.S IEC 60079-31	SOUTH AFRICA
70	CCG	Fixed Y	Adaptors; Type of Protection: Flameproof "db", Increased Safety "eb", Dust Ignition "ta" ; Marking: Ex db IIC Gb, Ex eb IIC	N/A	NA	ZA/ICS/QAR14.0001/10 IECEX TSA 23.0023U GB/CML/ExTR18.0203/00 GB/CML/ExTR16.0131/00 GB/CML/ExTR16.0073/00 GB/CML/ExTR22.0143/00	UAE.S IEC 60079-0, UAE.S IEC 60079-1, UAE.S	SOUTH AFRICA



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology





بيان التسجيل
SCHEDULE OF CERTIFICATION
Ministry of Industry and Advanced Technology

			Gb, Ex ta IIIC Da, Ex db I Mb, Ex eb I Mb, IP65 / IP66 / IP67 / IP68 - refer to Schedule of Limitations; For temperature details refer IECEx TSA 23.0023U				IEC 60079-7, UAE.S IEC 60079-31	
Nothing Follows								



جهة معينة من قبل وزارة الصناعة والتكنولوجيا المتقدمة
Notified body by Ministry of Industry and Advanced Technology

